

ERIC J. HOLCOMB, Governor
STATE OF INDIANA

INDIANA DEPARTMENT OF HOMELAND SECURITY
302 West Washington Street
Indianapolis, IN 46204



July 11, 2018
By U.S. Mail

Jessica Pontius
Daniel's Vineyard
9061 N 700 W
McCordsville, IN 46055

Re: Petition for Review – Inspect Report Order State Number AE3032758: Daniel's Vineyard

Dear Ms. Pontius:

The Commission is in receipt of your petition for review of Inspection Report Order State Number AE3032758: Daniel's Vineyard, dated 6/25/2018. The petition for review is timely and has been granted by the Commission. The petition has been assigned to the Commission's administrative law judge.

The judge's office will contact you to make arrangements for further proceedings. Should you have any questions, you may contact our staff attorney assigned to the matter, Justin Guedel at JGuedel@dhs.in.gov or (317) 234-9515.

Sincerely,

A handwritten signature in black ink, appearing to read 'D. J. Boyle', is positioned above the typed name of the Director.

Douglas J. Boyle, Director
Fire Prevention and Building Safety Commission
Indiana Department of Homeland Security
302 W. Washington Street, Room E-208
Indianapolis, IN 46204
doboyle@dhs.in.gov
(317) 650-7720

cc: Justin Guedel
ALJ
File

Monday, July 2, 2019

Attn: Department of Fire Prevention and Building Safety Commission
Provider Appeals Department
302 West Washington Street, Rm W246
Indianapolis, IN 46204

Violation Number: 1

Rule Code: 675 IAC 12-6-3 Sec 3. (a)

Identification Number: AE302758

Daniel's Vineyard

Hancock County

9061 N. 700 W. McCordsville, IN 46055

team@danielsvineyard.com

317-248-5222

Dear Appeals Department,

We are appealing your decision and request reconsideration of the attached violation that was received on June 25, 2018 by Mike Barnhart.

Thank you for reviewing this violation. If you require any additional information, please contact Jessica Pontius at jpontius@danielsvineyard.com or our mailing address.

Sincerely,

Jessica Pontius



General Manager

Daniel's Vineyard

9061 N. 700 W.

McCordsville, IN 46055

jpontius@danielsvineyard.com

317-248-5222 ext 3303



FIRE AND BUILDING CODE ENFORCEMENT INSPECTION REPORT ORDER

DIVISION OF FIRE AND BUILDING SAFETY
INDIANA DEPARTMENT OF HOMELAND SECURITY
302 WEST WASHINGTON STREET, RM E241
INDIANAPOLIS, IN 46204
TELEPHONE: 317-232-2222
WEB ADDRESS: WWW.IN.GOV/DHS

Identification Number AE3032758	Name of the facility DANIELS VINEYARD	County HANCOCK
Address of Property 9061 N 700 W MCCORDSVILLE IN 46055		Name of the Contact JESSICA PONTIUS
		Telephone Number (317) 248-5222
Email		Inspection Date 06/25/2018
Inspection Category ENTERTAINMENT PERMIT	Inspection Type ANNUAL	Inspection Status: VIOLATION
Name of the inspector MIKE BARNHART		Phone: 3174176664
Email: mbarnhart@dhs.in.gov		

Violations

VIO-LATION NUMBER	RULE OR INDIANA CODE SECTION VIOLATED	DESCRIPTION OF VIOLATION	DATE BY WHICH VIOLATION MUST BE CORRECTED
1	675 IAC 12-6-3 Sec. 3. (a)	Design release; requirement Authority: IC 22-13-2-13 Affected: IC 22-15-3 Sec. 3. (a) No construction shall be done on a Class 1 structure until a design release has been issued by the division unless the construction is of a type specifically exempted from the design release requirements by section 4 of this rule. <u>The outside stage consisting of three semi trailers connected together is considered a Class 1 structure and no Design Release was obtained prior to its construction.</u>	07/11/2018
2	Sec. 901.6.1 2014 Edition IFC 675 IAC 22-2.5	Fire protection systems shall be inspected, tested and maintained in accordance with the referenced standards listed in Table 901.6.1. <u>The sprinkler system is past due for an annual test and inspection.</u>	07/23/2018
3	Sec. 604.5.2 2014 Edition IFC 675 IAC 22-2.5	For battery-powered emergency lighting, a power test of the emergency lighting equipment shall be completed annually. The power test shall operate the emergency lighting for a minimum of 90 minutes and shall remain sufficiently illuminated for the duration of the test. <u>Documentation of a current 90 minute test on the emergency lights was not available for the inspector's review.</u>	07/23/2018

Inspection Notes:

Violations as noted.

Facility Id AE3032758	Received By Name	Signature and Date
---------------------------------	------------------	--------------------

Daniel's Vineyard
9061 N. 700 W.
McCordsville, IN 46055

INDIANAPOLIS IN 460

30 JUN 2018 PM 5:1



Appeals Department
Fire Prevention & Building Safety Comm.
302 West Washington Pm 2446
Indianapolis, IN 46204