# FIRE PREVENTION AND BUILDING SAFETY COMMISSION Department of Homeland Security

## Written Interpretation Of the State Building Commissioner

Interpretation #: CEB-2021-03-2014 IBC-1029.1

#### **Building or Fire Safety Law Interpreted**

675 IAC 13-2.6, 2014 Indiana Building Code, Section 1029.1 General. In addition to the *means of egress* required by this chapter, provisions shall be made for *emergency escape and rescue openings* in Group R-2 occupancies in accordance with Tables 1021.2(1) and 1021.2(2) and Group R-3 occupancies. [Remainder of section omitted for lack of relevance to the issue of this interpretation request.]

#### Issue

Whether a sleeping room in a fire station is required to have emergency escape and rescue openings under Section 1029.1 of the 2014 Indiana Building Code (IBC).

# Interpretation of the State Building Commissioner

A sleeping room in a fire station is not required to have emergency escape and rescue openings under Section 1029.1 of the 2014 IBC.

### Rationale

Section 304 of the 2014 IBC places fire stations in the B occupancy category, with no requirement that any sleeping rooms present in such facilities be classified differently. Since 1029.1 limits its own applicability to R-2 and R-3 occupancies, it does not apply to fire stations.

Posted: 03/03/2021 by Legislative Services Agency An <a href="https://html">httml</a> version of this document.

Date: Mar 05,2021 2:51:13PM EST DIN: 20210303-IR-675210071NRA Page 1